



Wayne-Westland Community Schools
 Drinking Water Analysis
 Project Number: AE170005

Eliot Elementary School
 Date of Sampling: April 5, 2017
 Sampler: Jessica Perfetti

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
EL-01	Bubbler in hallway across from Main Office	B	6:17 AM	15	3	N/A	First Draw
EL-02	Kitchen, left faucet, 3 compartment sink	KS	6:22 AM	15	5	Y	First Draw
EL-03	Kitchen, right faucet, 3 compartment sink	KS	6:22 AM	15	3	Y	First Draw
EL-04	Clinic, nurse sink	NS	6:29 AM	15	2	N	First Draw
EL-05	Principals Office	KS	6:34 AM	15	2	Y	First Draw
EL-06	Room 11 bubbler	B	6:39 AM	15	1	N/A	First Draw
EL-07	Bubbler in hallway between Rooms 3 & 2	B	6:43 AM	15	6	N/A	First Draw
EL-08	Room 4 bubbler	B	6:47 AM	15	7	N/A	First Draw
EL-09	Left bubbler in hallway near Room 17	B	6:53 AM	15	2	N/A	First Draw
EL-10	Right bubbler in hallway nearest to Room 16	B	6:57 AM	15	1	N/A	First Draw
EL-11	Room 13 bubbler	B	7:02 AM	15	ND ³	N/A	First Draw
EL-12	Room 12 bubbler	B	7:05 AM	15	4	N/A	First Draw
EL-13	Room 25, Staff Lounge	KS	7:11 AM	15	7	Y	First Draw
EL-14	Right bubbler, across from Room 26, in hallway	B	7:15 AM	15	2	N/A	First Draw
EL-15	Room 26 classroom faucet	CF	7:18 AM	15	3	Y	First Draw

1) Type: B = Bubbler, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested