



Wayne-Westland Community Schools
 Drinking Water Analysis
 Project Number: AE160005

Taft-Galloway Elementary School
Date of Sampling: November 15, 2016
Sampler: Brad Ziegler

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
TG - 01	Music Room	B	6:09 AM	15	ND ³	N	First Draw
TG - 02	Cooler Office C. North	WC	6:11 AM	15	ND	N	First Draw
TG - 03	Gym/Cafeteria	B	6:14 AM	15	1	N	First Draw
TG - 04	Teachers Lounge	CF	6:19 AM	15	ND	Y	First Draw
TG - 05	Room 103	B	6:24 AM	15	ND	N	First Draw
TG - 06	Room 106	CF	6:29 AM	15	ND	Y	First Draw
TG - 07	Room 107	B	6:33 AM	15	ND	N	First Draw
TG - 08	Upstairs Cooler Adjacent to Janitors Closest, East	WC	6:39 AM	15	ND	N	First Draw
TG - 09	Room 204	CF	6:43 AM	15	ND	Y	First Draw
TG - 10	Room 203	B	6:45 AM	15	ND	N	First Draw
TG - 11	Room 201	CF	6:49 AM	15	ND	N	First Draw
TG - 12	Room 200	B	6:52 AM	15	ND	N	First Draw
TG - 13	Room 102	CF	6:58 AM	15	ND	Y	First Draw
TG - 14	Kitchen West Tap	KS	7:02 AM	15	1	Y	First Draw
TG - 15	Optimum Room	CF	7:08 AM	15	ND	Y	First Draw

1) Type: B = Bubble, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink, SP = Sink Used for Drinking
 2) <http://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminates>
 3) ND = Non-Detect at Report Detection Limit of 1 ug/L