



Wayne-Westland Community Schools
 Drinking Water Analysis
 Project Number: AE170005

Wayne Memorial High School							
Date of Sampling: March 17, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
WM-01	Gym-northeast corner, outside girls locker room.	B	4:50 AM	15	2	N	First Draw
WM-02	Left of door 117, next to Distribution Center.	WC	5:06 AM	15	1	N	First Draw
WM-03	To the right of door 106, left water cooler.	WC	5:11 AM	15	ND ³	N	First Draw
WM-04	To the right of door 106, right water cooler.	WC	5:12 AM	15	ND	N	First Draw
WM-05	To the right of door 103	WC	5:16 AM	15	3	N	First Draw-low flow
WM-06	To the left of door 321 (science wing)	WC	5:26 AM	15	ND	N	First Draw
WM-07	To the left of door 334 (science wing)	WC	5:29 AM	15	ND	N	First Draw
WM-08	Next to door 218, across from media center.	WC	5:34 AM	15	1	N	First Draw
WM-09	Across from door 133	WC	5:42 AM	15	ND	N	First Draw
WM-10	Lower cafeteria, left of emergency exit door.	WC	5:49 AM	15	1	N	First Draw
WM-11	Lower cafeteria, sink behind concession stand.	KS	5:51 AM	15	2	N	First Draw
WM-12	Upper cafeteria, bottle fill station.	BT	5:57 AM	15	ND	N	First Draw
WM-13	Wrestling room, auxiliary gym	B	6:10 AM	15	6	N	First Draw
WM-14	Auditorium-lobby, left bubbler	B	6:30 AM	15	ND	N	First Draw
WM-15	Auditorium-lobby, right bubbler	B	6:31 AM	15	ND	N	First Draw

1) Type: B = Bubbler; WC = Water Cooler; CF = Classroom Faucet; KS = Kitchen Sink; ND = No Use Sink; DS = Sink used for Drinking
 2) <https://www.epa.gov/your-drinking-water/leak-regulated-drinking-water-contaminates>
 3) ND = Non-Detect at Report Detection Limit of 1 ug/L