



Wayne-Westland Community Schools  
 Drinking Water Analysis  
 Project Number: AE170005

Dyer Administration							
Date of Sampling: February 14, 2017							
Sampler: Lauren Koloski							
Sample #	Location	Type <sup>1</sup>	Time Collected	EPA Action Level (ug/L) <sup>2</sup>	Results (ug/L)	Aerator Present Y/N	Notes
AD-01	Bubbler in hall outside exit door 24, outside pool	B	6:11 AM	15	4	N/A	First Draw
AD-02	Right water cooler in hallway outside Board Meeting Room	WC	6:20 AM	15	1	N/A	First Draw
AD-03	Left water cooler in hallway outside Board Meeting Room	WC	6:21 AM	15	ND <sup>3</sup>	N/A	First Draw
AD-04	Staff Lounge sink	KS	6:28 AM	15	2	Y	First Draw
AD-05	Water cooler in Receiving Hallway	WC	6:30 AM	15	41	N/A	First Draw
AD-06	Business Office sink	KS	6:33 AM	15	ND	Y	First Draw
AD-07	Human Resource Lounge	KS	6:35 AM	15	ND	Y	First Draw
AD-08	Water cooler in hallway outside Administration and Child Care	WC	6:37 AM	15	ND	N/A	First Draw, Copper Staining
AD-09	Bubbler in Child Care	B	6:40 AM	15	1	N/A	First Draw
AD-10	Child Care Staff Lounge	KS	6:41 AM	15	ND	Y	First Draw
AD-11	Right water cooler in Senior Center	WC	6:45 AM	15	2	N/A	First Draw
AD-12	Left water cooler in Senior Center	WC	6:45 AM	15	ND	N/A	First Draw
AD-13	Kitchen sink Senior Center	KS	6:47 AM	15	ND	Y	First Draw
AD-14	Special Education Staff Lounge	KS	6:50 AM	15	ND	Y	First Draw
AD-15	Instruction Staff Lounge	KS	6:52 AM	15	ND	Y	First Draw

1) Type: B = Bubbler; WC = Water Cooler; CF = Classroom Faucet; KS = Kitchen Sink; NS = Nurse Sink; S = Sink used for Drinking  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non-Detect at Report Detection Limit of 1 ug/L