



Wayne-Westland Community Schools
 Drinking Water Analysis
 Project Number: AE160005

Roosevelt-McGrath Elementary School

Date of Sampling: November 15, 2016

Sampler: Lauren Koloski

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
RM - 01	Kitchen 1 Compartment Sink	KS	6:05 AM	15	2	Y	First Draw
RM - 02	Room 100	B	6:09 AM	15	ND ³	N	First Draw
RM - 03	Outside Room 110, Right	B	6:13 AM	15	20	N	First Draw
RM - 04	Room 113	B	6:15 AM	15	ND	N	First Draw
RM - 05	Outside Room 117, Right	B	6:19 AM	15	2	N	First Draw
RM - 06	Room 120	B	6:22 AM	15	ND	N	First Draw
RM - 07	Outside Room 7	B	6:26 AM	15	ND	N	First Draw
RM - 08	Outside Room 125	B	6:30 AM	15	2	N	First Draw
RM - 09	Room 126	CF	6:36 AM	15	7	Y	First Draw
RM - 10	Room 132	B	6:39 AM	15	10	N	First Draw
RM - 11	Staff Lounge	CF	6:42 AM	15	ND	Y	First Draw
RM - 12	Gym Fountain	B	6:45 AM	15	ND	N	First Draw
RM - 13	Nurse Sink	B	6:49 AM	15	ND	N	First Draw
RM - 14	Room 118	B	6:54 AM	15	ND	N	First Draw
RM - 15	Room 111	B	6:57 AM	15	ND	N	First Draw

1) Type: B = Bubble, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink, SF = Sink Used for Drinking
 2) <http://www.epa.gov/yourdrinkingwater/epa-reg-water-drinking-water-contaminates>
 3) ND = Non-Detect at Report Detection Limit of 1 ug/L