



Wayne-Westland Community Schools
Drinking Water Analysis
Project Number: AE170005

Bus Garage							
Date of Sampling: February 21, 2017							
Sampler: Lauren Koloski							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
BUS-01	Kitchen water cooler	WC	5:17 AM	15	ND ³	N/A	First Draw
BUS-02	Kitchen water cooler bottle fill	BF	5:18 AM	15	ND	N/A	First Draw

1) Type: B – Bubbler, BF – Bottle Fill, CF – Classroom Faucet, KS – Kitchen Sink, NS – Nurse Sink, S – Sink Used for Drinking

2) <https://www.epa.gov/dwstandardsregulations/secondary-drinking-water-standards-guidance-nuisance-chemicals>

3) ND = Non Detected at Reported Detection Limit of 1 ug/L

4) NT = Not Tested